



Legislation Details (With Text)

File #:	Int 1098-2013	Version:	A	Name:	Preventing the backflow of sewage.
Type:	Introduction	Status:	Enacted	In control:	Committee on Housing and Buildings
On agenda:	6/24/2013				
Enactment date:	10/2/2013	Enactment #:	2013/083		
Title:	A Local Law to amend the New York city plumbing code and the New York city building code, in relation to preventing the backflow of sewage.				
Sponsors:	Donovan J. Richards, Margaret S. Chin, Letitia James, Peter A. Koo, G. Oliver Koppell, Brad S. Lander, Rosie Mendez, Deborah L. Rose, Gale A. Brewer, Robert Jackson, Melissa Mark-Viverito, Jumaane D. Williams, Charles Barron, Mathieu Eugene, James F. Gennaro, Darlene Mealy, James G. Van Bramer, Elizabeth S. Crowley				
Indexes:					
Attachments:	1. Int. No. 1098 - 6/24/13, 2. Committee Report 6/27/13, 3. Hearing Testimony 6/27/13, 4. Hearing Transcript 6/27/13, 5. Committee Report 9/24/13, 6. Hearing Transcript 9/24/13, 7. Committee Report - Stated Meeting, 8. Fiscal Impact Statement, 9. Mayor's Letter, 10. Hearing Transcript - Stated Meeting 9-24-13, 11. Local Law 83				

Date	Ver.	Action By	Action	Result
6/24/2013	*	City Council	Introduced by Council	
6/24/2013	*	City Council	Referred to Comm by Council	
6/27/2013	*	Committee on Housing and Buildings	Hearing Held by Committee	
6/27/2013	*	Committee on Housing and Buildings	Laid Over by Committee	
6/27/2013	*	Committee on Environmental Protection	Hearing Held by Committee	
6/27/2013	*	Committee on Environmental Protection	Laid Over by Committee	
6/27/2013	*	Committee on Parks and Recreation	Hearing Held by Committee	
6/27/2013	*	Committee on Parks and Recreation	Laid Over by Committee	
6/27/2013	*	Committee on Transportation	Hearing Held by Committee	
6/27/2013	*	Committee on Transportation	Laid Over by Committee	
6/27/2013	*	Committee on Waterfronts	Hearing Held by Committee	
6/27/2013	*	Committee on Waterfronts	Laid Over by Committee	
9/24/2013	*	Committee on Housing and Buildings	Hearing Held by Committee	
9/24/2013	*	Committee on Housing and Buildings	Amendment Proposed by Comm	
9/24/2013	*	Committee on Housing and Buildings	Amended by Committee	
9/24/2013	A	Committee on Housing and Buildings	Approved by Committee	Pass

9/24/2013	A	City Council	Approved by Council	Pass
9/24/2013	A	City Council	Sent to Mayor by Council	
10/2/2013	A	Mayor	Hearing Held by Mayor	
10/2/2013	A	Mayor	Signed Into Law by Mayor	
10/2/2013	A	City Council	Recved from Mayor by Council	

Int. No. 1098-A

By Council Members Richards, Chin, James, Koo, Koppell, Lander, Mendez, Rose, Brewer, Jackson, Mark-Viverito, Williams, Barron, Eugene, Gennaro, Mealy, Van Bramer and Crowley

A Local Law to amend the New York city plumbing code and the New York city building code, in relation to preventing the backflow of sewage.

Be it enacted by the Council as follows:

Section 1. Section 715.1 of the New York city plumbing code, as added by local law number 99 for the year 2005, is amended to read as follows:

715.1 Sewage backflow. Where fixtures, floor drains, or area drains are subject to overflow as the result of backwater from the public sewer system, accessible backwater valves shall be installed in the fixture drain pipe from such fixture, in the branch drain to such area drain or group of fixtures, or in the building drain at its point of exit from the building and downstream from the building trap. Buildings located in areas of special flood hazard, as established by Section G102.2 of Appendix G of the *New York City Building Code*, shall be deemed to be subject to overflow as the result of backwater from the public sewer system and shall be provided with backwater valves in accordance with the requirements of Section 7.3.3 of ASCE 24 as modified by Appendix G of the *New York City Building Code*.

§ 2. The New York city plumbing code is amended by adding a new section 1101.9.1 to read as follows:

1101.9.1 Backwater valves in special flood hazard areas. Backwater valves shall be installed in storm drainage systems in accordance with Section 7.3.4 of ASCE 24 as modified by Appendix G of the *New York City Building Code* for all buildings located in the areas of special flood hazard, as established by Section G102.2 of Appendix G of the *New York City Building Code*.

§ 3. Section BC G501.1 of the New York city building code, as added by local law number 33 for the year 2007, is amended by adding two new amendments to sections 7.3.3 and 7.3.4 of ASCE 24-05 to read as follows:

Section 7.3.3. Section 7.3.3 is amended to read as follows:

7.3.3 Plumbing Systems Installed Below Minimum Elevations. Plumbing systems and components, including plumbing fixtures, shall be elevated above the elevation specified in Table 7-1. Where plumbing systems and components have openings below the elevation specified in Table 7-1, the openings shall be protected with automatic backwater valves or other automatic backflow devices. Devices shall be installed in each line that extends below the DFE to prevent release of sewage into floodwaters and to prevent infiltration by floodwaters into the plumbing. Redundant devices requiring human intervention shall be permitted. Plumbing systems shall be provided with backwater valves in the building drain at its point of exit from the building and downstream of the building trap.

Section 7.3.4. Section 7.3.4 is amended to read as follows:

7.3.4 Sanitary Systems. Sanitary systems shall be designed to minimize infiltration of flood waters into the systems and discharges from the systems into floodwaters. Vents and openings shall be above the elevation specified in Table 7-1. Sanitary system storage tanks shall be designed, constructed, installed, and anchored to resist at least 1.5 times the potential buoyant and other flood forces acting on an empty tank during design flood conditions. Tanks and piping shall be installed to resist local scour and erosion. Sanitary systems shall be provided with backwater valves at the point of exit from the building and downstream of the building trap. Sanitary systems that must remain operational during or immediately after the design flood or lesser floods shall be equipped with a sealed storage tank that is sized to store at least 150% of the anticipated sewage flow associated with occupancy during flood conditions and during subsequent periods of saturated soil when sewage

will not percolate.

§ 4. This local law shall take effect ninety days after its enactment.

SS