



Legislation Details (With Text)

File #: Int 1277-2016 **Version:** A **Name:** Conforming the New York city energy conservation code to recent amendments to the 2016 New York state energy code.

Type: Introduction **Status:** Enacted
In control: Committee on Housing and Buildings

On agenda: 9/14/2016

Enactment date: 10/18/2016 **Enactment #:** 2016/125

Title: A Local Law to amend the administrative code of the city of New York, in relation to conforming the New York city energy conservation code to recent amendments to the 2016 New York state energy code.

Sponsors: Jumaane D. Williams, Rafael Salamanca, Jr., James G. Van Bramer, Brad S. Lander, Ben Kallos, Inez D. Barron, (by request of the Mayor)

Indexes:

Attachments: 1. Legislative History Report, 2. Summary of Int. No. 1277, 3. Int. No. 1277 - 9/14/16, 4. September 14, 2016 - Stated Meeting Agenda with Links to Files, 5. Committee Report 9/15/16, 6. Hearing Testimony 9/15/16, 7. Hearing Transcript 9/15/16, 8. Committee Report 9/26/16, 9. Hearing Testimony 9/26/16, 10. Hearing Transcript 9/26/16, 11. September 28, 2016 - Stated Meeting Agenda with Links to Files, 12. Committee Report - Stated Meeting, 13. Fiscal Impact Statement, 14. Int. No. 1277-A (FINAL), 15. Hearing Transcript - Stated Meeting 9-28-16, 16. Mayor's Letter, 17. Minutes of the Stated Meeting - September 28, 2016, 18. Local Law 125

Date	Ver.	Action By	Action	Result
9/14/2016	*	City Council	Introduced by Council	
9/14/2016	*	City Council	Referred to Comm by Council	
9/15/2016	*	Committee on Housing and Buildings	Laid Over by Committee	
9/15/2016	*	Committee on Housing and Buildings	Hearing Held by Committee	
9/26/2016	*	Committee on Housing and Buildings	Hearing Held by Committee	
9/26/2016	*	Committee on Housing and Buildings	Amendment Proposed by Comm	
9/26/2016	*	Committee on Housing and Buildings	Amended by Committee	
9/26/2016	A	Committee on Housing and Buildings	Approved by Committee	Pass
9/28/2016	A	City Council	Approved by Council	Pass
9/28/2016	A	City Council	Sent to Mayor by Council	
10/18/2016	A	Mayor	Hearing Held by Mayor	
10/18/2016	A	Mayor	Signed Into Law by Mayor	
10/19/2016	A	City Council	Recved from Mayor by Council	

Int. No. 1277-A

By Council Members Williams, Salamanca, Van Bramer, Lander, Kallos and Barron (by request of the Mayor)

A Local Law to amend the administrative code of the city of New York, in relation to conforming the New York city energy conservation code to recent amendments to the 2016 New York state energy code.

Be it enacted by the Council as follows:

Section 1. Section 28-1001.1.1 of the administrative code of the city of New York, as added by local law number 91 for the year 2016, is amended to read as follows:

§28-1001.1.1 Definition. As used in this chapter, the term “New York State Energy Code” means the New York State Energy Conservation Construction Code (the “New York State Energy Code”), constituting part 1240 of title 19 of the New York codes, rules and regulations (19 NYCRR Part 1240), and the publications incorporated by reference in such part, promulgated on [April 6, 2016] September 21, 2016, by the State Fire Prevention and Building Code Council pursuant to Article 11 of the New York State Energy Law.

§ 2. The New York city amendments to Table C403.2.3(3) of the New York state energy code, as added by local law 91 for the year 2016, are amended to read as follows:

Table C403.2.3(3) MINIMUM EFFICIENCY REQUIREMENTS: ELECTRICALLY OPERATED PACKAGED TERMINAL AIR CONDITIONERS, PACKAGED TERMINAL HEAT PUMPS, SINGLE-PACKAGE VERTICAL AIR CONDITIONERS, SINGLE-PACKAGE VERTICAL HEAT PUMPS, ROOM AIR CONDITIONERS, AND ROOM AIR-CONDITIONER HEAT PUMPS

Delete Table C403.2.3(3) in its entirety and replace with a new Table C403.2.3(3) to read as follows:

TABLE C403.2.3(3)

MINIMUM EFFICIENCY REQUIREMENTS: ELECTRICALLY OPERATED PACKAGED TERMINAL AIR CONDITIONERS, PACKAGED TERMINAL HEAT PUMPS, SINGLE-PACKAGE VERTICAL AIR CONDITIONERS, SINGLE-PACKAGE VERTICAL HEAT PUMPS, ROOM AIR CONDITIONERS AND ROOM AIR-CONDITIONER HEAT PUMPS

EQUIPMENT TYPE	SIZE CATEGORY (INPUT)	SUBCATEGORY OR RATING CONDITION	MINIMUM EFFICIENCY	TEST PROCEDURE ^a
PTAC (cooling mode) standard size	All Capacities	95°F db outdoor air	14.0 - (0.300 × Cap/1000) EER ^c	AHRI 310/380
PTAC (cooling mode) nonstandard size ^b	All Capacities	95°F db outdoor air	10.9 - (0.213 × Cap/1000) ^[c] EER	
PTHP (cooling mode) standard size	All Capacities	95°F db outdoor air	14.0 - (0.300 × Cap/1000) ^[c] EER	

PTHP (cooling mode) nonstandard size ^b	All Capacities	95°F db outdoor air	$10.8 - (0.213 \times \text{Cap}/1000)^{[c]}$ EER	
PTHP (heating mode) standard size	All Capacities	-	$3.7 - (0.052 \times \text{Cap}/1000)^{[c]}$ COP _H	
PTHP (heating mode) nonstandard size ^b	All Capacities	-	$2.9 - (0.026 \times \text{Cap}/1000)^{[c]}$ COP _H	
SPVAC (cooling mode)	< 65,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	AHRI 390
	≥ 65,000 Btu/h and < 135,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
	≥ 135,000 Btu/h and < 245,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
SPVHP (cooling mode)	< 65,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
	≥ 65,000 Btu/h and < 135,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
	≥ 135,000 Btu/h and < 245,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
SPVHP (heating mode)	< 65,000 Btu/h	47°F db/43°F wb outdoor air	3.0 COP _H	AHRI 390
	≥ 65,000 Btu/h and < 135,000 Btu/h	47°F db/43°F wb outdoor air	3.0 COP _H	
	≥ 135,000 Btu/h and < 245,000 Btu/h	47°F db/75°F wb outdoor air	3.0 COP _H	
SPVAV (cooling mode) nonweatherized space constrained	[<] ≤ 30,000 Btu/h	95°F db/75°F wb outdoor air	9.2 EER	
	> 30,000 Btu/h and [<] ≤ 36,000 Btu/h	95°F db/75°F wb outdoor air	9.0 EER	
SPVHP (cooling mode) nonweatherized space constrained	[<] ≤ 30,000 Btu/h	95°F db/75°F wb outdoor air	9.2 EER	

	> 30,000 Btu/h and [\leq] 36,000 Btu/h	95°F db/75°F wb outdoor air	9.0 EER	
SPVHP (heating mode) nonweatherized space constrained	[\leq] 30,000 Btu/h	47°F db/43°F wb outdoor air	3.0 COP _H	
	> 30,000 Btu/h and [\leq] 36,000 Btu/h	47°F db/43°F wb outdoor air	3.0 COP _H	
Room air conditioners, with louvered sides	< 6,000 Btu/h	-	11.0 CEER	10 CFR Part 430
	\geq 6,000 Btu/h and < 8,000 Btu/h	-	11.0 CEER	
	\geq 8,000 Btu/h and < 14,000 Btu/h	-	10.9 CEER	
	\geq 14,000 Btu/h and < 20,000 Btu/h	-	10.7 CEER	
	\geq 20,000 Btu/h and < 24,000 Btu/h	-	9.4 CEER	
	\geq 25,000 Btu/h	-	9.0 CEER	10 CFR Part 430
Room air conditioners, without louvered sides	< 6,000 Btu/h	-	10.0 CEER	
	\geq 6,000 Btu/h and < 8,000 Btu/h	-	10.0 CEER	
	\geq 8,000 Btu/h and < 11,000 Btu/h	-	9.6 CEER	
	\geq 11,000 Btu/h and < 14,000 Btu/h	-	9.5 CEER	
	\geq 14,000 Btu/h and < 20,000 Btu/h	-	9.3 CEER	
	\geq 20,000 Btu/h	-	9.4 CEER	

Room air-conditioner heat pumps, with louvered sides	< 20,000 Btu/h	-	9.8 CEER	10 CFR Part 430
	≥ 20,000 Btu/h	-	9.3 CEER	
Room air-conditioner heat pumps, without louvered sides	< 14,000 Btu/h	-	9.3 CEER	
	≥ 14,000 Btu/h	-	8.7 CEER	
Casement-only	All capacities	-	9.5 CEER	
Casement-slider	All capacities	-	10.4 CEER	

For SI: 1 British thermal unit per hour = 0.2931 W, °C = [(°F) - 32]/1.8, wb = wet bulb, db = dry bulb.

“Cap” = The rated cooling capacity of the project in Btu/h. Where the unit’s capacity is less than 7000 Btu/h, use 7000 Btu/h in the calculation. Where the unit’s capacity is greater than 15,000 Btu/h, use 15,000 Btu/h in the calculations.

- a. Chapter 6 contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure.
- b. Nonstandard size units must be factory labeled as follows: “MANUFACTURED FOR NONSTANDARD SIZE APPLICATIONS ONLY; NOT TO BE INSTALLED IN NEW STANDARD PROJECTS.” Nonstandard size efficiencies apply only to units being installed in existing sleeves having an external wall opening of less than 16 in. high or less than 42 in. wide and having a cross-sectional area less than 670 in.².
- c. Before January 1, 2015 the minimum efficiency shall be 13.8 - (0.300 x Cap/1000) EER.

§ 3. Section 28-1001.2.2 of the administrative code of the city of New York, as added by local law 91 for the year 2016, is amended by adding New York city amendments to Section C406.7.1 of the New York State energy code to read as follows:

C406.7.1 Load Fraction.

Section C406.7.1 - Revise the first sentence of Section C406.7.1 to read as follows:

The building service water-heating system shall have one or more of the following that are sized to provide not less than 60 percent of hot water requirements, or sized to provide 100 percent of hot water requirements if the building shall otherwise comply with Section C403.4.5.

§ 4. Section 28-1001.2.2 of the administrative code of the city of New York, as added by local law 91 for the year 2016, is amended by adding New York city amendments to Section 4.2.1.1 of the New York State energy code to read as follows:

Section 4 - ADMINISTRATION AND ENFORCEMENT

4.2.1.1 New Buildings.

Section 4.2.1.1 - Delete Section 4.2.1.1 in its entirety and replace with a new Section 4.2.1.1 to read as follows:

New buildings shall comply with either the provisions of

a. Section 5, “Building Envelope”; Section 6, “Heating, Ventilating, and Air Conditioning”; Section 7, “Service Water Heating”; Section 8, “Power”; Section 9, “Lighting”; and Section 10, “Other Equipment”;
or

b. Section 11, “Energy Cost Budget Method”; or

c. Appendix G, “Performance Rating Method.”

When using Appendix G, the Performance Cost Index (PCI) shall be less than or equal to the Performance Cost Index Target (PCIt) when calculated in accordance with the following:

$$\text{PCI}_t = (\text{BBUEC} + (\text{BPF} \times \text{BBREC}))/\text{BBP}$$

Where:

PCI = Performance Cost Index calculated in accordance with Section G1.2.

BBUEC = Baseline Building Unregulated Energy Cost. The portion of the annual energy cost of a baseline building design that is due to unregulated energy use.

BBREC = Baseline Building Regulated Energy Cost. The portion of the annual energy cost of a baseline building design that is due to regulated energy use.

BPF = Building Performance Factor from Table 4.2.1.1. For building area types not listed in Table 4.2.1.1 use “All others.” Where a building has multiple building area types, the required BPF shall be equal to the area-weighted average of the building area types.

BBP = baseline building performance.

Regulated energy cost shall be calculated by multiplying the total energy cost by the ratio of regulated energy use to total energy use for each fuel type. Unregulated energy cost shall be calculated by subtracting regulated energy cost from total energy cost.

§ 5. The New York city amendments to Table 6.8.1-4 of the New York state energy code, as added by local law 91 for the year 2016, are amended to read as follows:

Table 6.8.1-4 Electrically Operated Packaged Terminal Air Conditioners, Packaged Terminal Heat Pumps, Single-Package Vertical Air Conditioners, Single-Package Vertical Heat Pumps, Room Air Conditioners, and Room Air-Conditioner Heat Pumps-Minimum Efficiency Requirements

Revise Table 6.8.1-4 to read as follows:

TABLE 6.8.1-4

Electrically Operated Packaged Terminal Air Conditioners, Packaged Terminal Heat Pumps, Single-Package Vertical Air Conditioners, Single-Package Vertical Heat Pumps, Room Air Conditioners, and Room Air-Conditioner Heat Pumps-Minimum Efficiency Requirements

Equipment Type	Size Category	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure ^a
PTAC (cooling mode) standard size	All capacities	95°F db outdoor air	14.0 - $(0.300 \times \text{Cap}/1000)^c$	AHRI 310/380
PTAC (cooling mode) nonstandard size ^b	All capacities	95°F db outdoor air	10.9 - $(0.213 \times \text{Cap}/1000)^c$ EER	
PTHP (cooling mode) standard size	All capacities	95°F db outdoor air	14.0 - $(0.300 \times \text{Cap}/1000)^c$	
PTHP (cooling mode) nonstandard size ^b	All capacities	95°F db outdoor air	10.8 - $(0.213 \times \text{Cap}/1000)^c$	
PTHP (heating mode) standard size	All capacities	_____	3.7 - $(0.052 \times \text{Cap}/1000)^c \text{COP}_H$	
PTHP (heating mode) nonstandard size ^b	All capacities	_____	2.9 - $(0.026 \times \text{Cap}/1000)^c \text{COP}_H$	
SPVAC (cooling mode)	< 65,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	AHRI 390
	≥ 65,000 Btu/h and < 135,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
	≥ 135,000 Btu/h and < 245,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
SPVHP (cooling mode)	< 65,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
	≥ 65,000 Btu/h and < 135,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
	≥ 135,000 Btu/h and < 245,000 Btu/h	95°F db/75°F wb outdoor air	10.0 EER	
SPVHP (heating mode)	< 65,000 Btu/h	47°F db/43°F wb outdoor air	3.0 COP_H	

	$\geq 65,000$ Btu/h 47°F db/43°F wb 3.0 COP _H and < 135,000 outdoor air Btu/h			
	$\geq 135,000$ 47°F db/43°F wb 3.0 COP _H Btu/h and < outdoor air 245,000 Btu/h			
SPVAC (cooling mode), nonweatherized space constrained	$[<]\leq 30,000$ Btu/h	95°F db/75°F wb outdoor air	9.2 EER	AHRI 390
	$> 30,000$ Btu/h and $[<]\leq 36,000$ Btu/h	95°F db/75°F wb outdoor air	9.0 EER	
SPVHP (cooling mode) , nonweatherized space constrained	$[<]\leq 30,000$ Btu/h	95°F db/75°F wb outdoor air	9.2 EER	
	$> 30,000$ Btu/h and $[<]\leq 36,000$ Btu/h	95°F db/75°F wb outdoor air	9.0 EER	
SPVHP (heating mode) , nonweatherized space constrained	$[<]\leq 30,000$ Btu/h	47°F db/43°F wb outdoor air	3.0 COP _H	
	$> 30,000$ Btu/h and $[<]\leq 36,000$ Btu/h	47°F db/43°F wb outdoor air	3.0 COP _H	
Room air conditioners, with louvered sides	< 6,000 Btu/h	_____	11.0 CEER	10 CFR Part 430
	$\geq 6,000$ Btu/h and < 8,000 Btu/h	_____	11.0 CEER	
	$\geq 8,000$ Btu/h and < 14,000 Btu/h	_____	10.9 CEER	
	$\geq 14,000$ Btu/h and < 20,000 Btu/h	_____	10.7 CEER	
	$\geq 20,000$ Btu/h and < 24,000 Btu/h	_____	9.4 CEER	
	$\geq 25,000$ Btu/h	_____	9.0 CEER	

Room air conditioners, without louvered sides	< 6,000 Btu/h _____	10.0 CEER	10 CFR Part 430
	≥ 6,000 Btu/h _____ and < 8,000 Btu/h	10.0 CEER	
	≥ 8,000 Btu/h _____ and < 11,000 Btu/h	9.6 CEER	
	≥ 11,000 Btu/h _____ and < 14,000 Btu/h	9.5 CEER	
	≥ 14,000 Btu/h _____ and < 20,000 Btu/h	9.3 CEER	
	≥ 20,000 Btu/h _____	9.4 CEER	
Room air conditioner heat pumps, with louvered sides	< 20,000 Btu/h _____	9.8 CEER	
	≥ 20,000 Btu/h _____	9.3 CEER	10 CFR Part 430
Room air conditioner heat pumps, without louvered sides	< 14,000 Btu/h _____	9.3 CEER	
	≥ 14,000 Btu/h _____	8.7 CEER	10 CFR Part 430
Casement-only	All capacities _____	9.5 CEER	10 CFR Part 430
Casement-slider	All capacities _____	10.4 CEER	

a. Section 12 contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure.

b. Nonstandard size units must be factory labeled as follows: “MANUFACTURED FOR NONSTANDARD SIZE APPLICATIONS ONLY; NOT TO BE INSTALLED IN NEW STANDARD PROJECTS.” Nonstandard size efficiencies apply only to units being installed in existing sleeves having an external wall opening of less than 16 in. high or less than 42 in. wide and having a cross-sectional area less than 670 in.².

c. “Cap” means the rated cooling capacity of the product in Btu/h. If the unit’s capacity is less than 7000 Btu/h, use 7000 Btu/h in the calculation. If the unit’s capacity is greater than 15,000 Btu/h, use 15,000 Btu/h in the calculation.

§ 6. The New York city amendments to Section R202 of the New York state energy code, as added by local law 91 for the year 2016, are amended to read as follows:

SECTION R202 GENERAL DEFINITIONS

Delete the definitions of “2016 Uniform Code Supplement,” “2015 International Building Code (As Amended),” “2015 International Fire Code (As Amended),” “2015 International Fuel Gas Code (As Amended),” “2015 International Mechanical Code (As Amended),” “2015 International Plumbing Code (As Amended),” “2015 International Property Maintenance Code (As Amended),” and “2015 International

Residential Code (As Amended).”

Revise the definition of “Approved” after the definition of “Alteration,” to read as follows:

APPROVED. See Section 28-101.5 of the Administrative Code.

Add a new definition of “Approved agency” after the definition of “Approved,” to read as follows:

APPROVED AGENCY. See Section 28-101.5 of the Administrative Code.

Delete the definitions of “ASHRAE 90.1-2013” and “ASHRAE 90.1-2013 (As amended)” after the definition of “Area weighted average.”

Add a new definition of “Authority having jurisdiction” after the definition of “Area weighted average” to read as follows:

AUTHORITY HAVING JURISDICTION. The commissioner or the commissioner’s designee.

Revise the definition of “Building site” after the definition of “Building,” to read as follows:

BUILDING SITE. A contiguous area of land that is under the ownership or control of one entity.

Revise the definition of “Building thermal envelope” after the definition of “Building [site] system,” to read as follows:

BUILDING THERMAL ENVELOPE. The exterior walls (above and below grade), floor, roof, and any other building elements that enclose conditioned space or provide a boundary between conditioned space and exempt or unconditioned space.

Revise the term “Code official” after the definition of “Climate Zone,” to read as follows:

CODE OFFICIAL. The commissioner or the commissioner’s designee.

Delete the definition of “Energy code”, after the definition of “Energy Analysis.”

Add a new definition of “Grade plane” after the definition of “General lighting,” to read as follows:

GRADE PLANE. A reference plane representing the average of finished ground level adjoining the building at exterior walls. Where the finished ground level slopes away from the exterior walls, the reference plane shall be established by the lowest points within the area between the building and the lot line or, where the lot line is more than 6 feet (1829 mm) from the building, between the building and a point 6 feet (1829 mm) from the building.

Add a new definition of “Lead energy professional” after the definition of “Labeled,” to read as follows:

LEAD ENERGY PROFESSIONAL. The registered design professional who signs and seals the energy analysis for an entire project. Such individual may be the same registered design professional who signs and seals the design drawings for the same project.

Add new definitions of “Professional certification” and “Project” after the definition of "Manual," to read as follows:

PROFESSIONAL CERTIFICATION. See Section 28-101.5 of the Administrative Code.

PROJECT. A design and construction undertaking comprised of work related to one or more buildings and the site improvements. A project is represented by one or more plan/work applications, including construction documents compiled in accordance with Section 107 of the New York City Building Code, that relate either to the construction of a new building or buildings or to the demolition or alteration of an existing building or buildings. Applications for a project may have different registered design professionals and different job numbers, and may result in the issuance of one or more permits.

Delete the definition of “Uniform Code.”

§ 7. The New York city amendments to the entry for “NYS”, of the New York state energy code, as added by local law 91 for the year 2016, are amended to read as follows

NYS	New York Department of State One Commerce Plaza, 99 Washington Ave Albany, NY 12231-0001	
	Standard reference number	Title
BCNYS-10	Building Code of New York State	Referenced in code section number
ECCCNYS- 16	New York State Energy Conservation Construction Code	R202 CH1 (Intro Statement), 101.1.1, 101.2.2, [101.3, C202] <u>R202</u>

§ 8. This local law takes effect on October 3, 2016, and applies to applications filed on and after October 3, 2016, but if it becomes a law after October 3, 2016, it takes effect immediately, and is retroactive to and shall be deemed to have been in full force and effect on and after October 3, 2016, and shall apply to applications filed on and after October 3, 2016.