



Legislation Details (With Text)

File #:	Int 1099-2013	Version:	A	Name:	Preventing wind damage to certain buildings and systems.
Type:	Introduction	Status:	Enacted	In control:	Committee on Housing and Buildings
On agenda:	6/24/2013				
Enactment date:	11/19/2013	Enactment #:	2013/101		
Title:	A Local Law to amend the New York city building code and the New York city mechanical code, in relation to preventing wind damage to certain buildings and systems.				
Sponsors:	Donovan J. Richards, Margaret S. Chin, Letitia James, Peter A. Koo, Brad S. Lander, Rosie Mendez, Domenic M. Recchia, Jr., Deborah L. Rose, Charles Barron, James G. Van Bramer, James F. Gennaro, Ydanis A. Rodriguez, Robert Jackson, Jumaane D. Williams				
Indexes:					
Attachments:	1. Int. No. 1099 - 6/24/13, 2. Committee Report 6/27/13, 3. Hearing Testimony 6/27/13, 4. Hearing Transcript 6/27/13, 5. Committee Report 10/30/13, 6. Hearing Transcript 10/30/13, 7. Committee Report - Stated Meeting, 8. Fiscal Impact Statement, 9. Hearing Transcript - Stated Meeting 10-30-13, 10. Mayor's Letter, 11. Local Law 101				

Date	Ver.	Action By	Action	Result
6/24/2013	*	City Council	Introduced by Council	
6/24/2013	*	City Council	Referred to Comm by Council	
6/27/2013	*	Committee on Housing and Buildings	Hearing Held by Committee	
6/27/2013	*	Committee on Housing and Buildings	Laid Over by Committee	
6/27/2013	*	Committee on Environmental Protection	Hearing Held by Committee	
6/27/2013	*	Committee on Environmental Protection	Laid Over by Committee	
6/27/2013	*	Committee on Parks and Recreation	Hearing Held by Committee	
6/27/2013	*	Committee on Parks and Recreation	Laid Over by Committee	
6/27/2013	*	Committee on Transportation	Hearing Held by Committee	
6/27/2013	*	Committee on Transportation	Laid Over by Committee	
6/27/2013	*	Committee on Waterfronts	Hearing Held by Committee	
6/27/2013	*	Committee on Waterfronts	Laid Over by Committee	
10/30/2013	*	Committee on Housing and Buildings	Hearing Held by Committee	
10/30/2013	*	Committee on Housing and Buildings	Amendment Proposed by Comm	
10/30/2013	*	Committee on Housing and Buildings	Amended by Committee	
10/30/2013	A	Committee on Housing and Buildings	Approved by Committee	Pass

10/30/2013	A	City Council	Approved by Council	Pass
10/30/2013	A	City Council	Sent to Mayor by Council	
11/19/2013	A	Mayor	Hearing Held by Mayor	
11/19/2013	A	Mayor	Signed Into Law by Mayor	
11/19/2013	A	City Council	Recved from Mayor by Council	

Int. No. 1099-A

By Council Members Richards, Chin, James, Koo, Lander, Mendez, Recchia, Rose, Barron, Van Bramer, Gennaro, Rodriguez, Jackson and Williams

A Local Law to amend the New York city building code and the New York city mechanical code, in relation to preventing wind damage to certain buildings and systems.

Be it enacted by the Council as follows:

Section 1. Section 1609.1.2 of the New York city building code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended to read as follows:

1609.1.2 [Reserved.] Protection from wind borne debris. The following buildings shall be protected with an impact-resistant covering or glazing in accordance with the Missile Levels and Wind Zones specified in ASTM E1886 and ASTM E1996 or other approved test methods and performance criteria:

1. Buildings in Structural Occupancy Category IV, as defined in Table 1604.5, located in Exposure C or D, as defined in Section 1609.4;

2. Buildings in Structural Occupancy Category III, as defined in Table 1604.5, located in Exposure D, as defined in Section 1609.4, where the glazing of such building encloses places of assembly for 300 or more persons or areas of in-place shelter.

Exception: Glazing protection in accordance with Section 1609.1.2 shall not be required if the glazing is located more than 60 feet (18 288 mm) above the ground and more than 30 feet (9144 mm) above aggregate-surfaced roofs, including roofs with gravel or stone ballast located within 1,500 feet (457.2

m) of the building.

1609.1.2.1 Louvers. Louvers protecting intake and exhaust ventilation ducts not assumed to be open that are located within 30 feet (9144 mm) of grade shall meet the requirements of an approved impact-resisting standard or the large missile test of ASTM E 1996.

1609.1.2.2 Garage doors. Garage door glazed opening protection for wind-borne debris shall meet the requirements of an approved impact-resisting standard or ANSI/DASMA 115.

§ 2. Chapter 4 of the New York city mechanical code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended by adding a new section 401.6.1 to read as follows:

401.6.1 Wind-driven rain rating. All exterior louvers for building ventilation systems shall either:

1. Receive an A rating according to AMCA Standard 550 for wind-driven rain penetration for a 50 mile per hour (80.4 km/h) wind velocity with a rainfall rate of eight inches (203 mm) per hour; or
2. Be installed on a plenum configured to intercept any wind-driven rain penetrating the louver and to prevent the rain from entering the building ductwork system. Such plenum shall be waterproofed and equipped with a drainage system to convey water penetrating the louver to storm or sanitary drains.

§ 3. Chapter 5 of the New York city mechanical code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended by adding a new section 501.2.2.1 to read as follows:

501.2.2.1 Wind-driven rain rating. All exterior louvers for building exhaust systems shall either:

1. Receive an A rating according to AMCA Standard 550 for wind-driven rain penetration for a 50 mile per hour (80.4 km/h) wind velocity with a rainfall rate of eight inches (203 mm) per hour; or
2. Be installed on a plenum configured to intercept any wind-driven rain penetrating the louver and to prevent the rain from entering the building ductwork system. Such plenum shall be waterproofed and equipped with a drainage system to convey water penetrating the louver to storm or sanitary drains.

§ 4. Chapter 35 of the New York city building code, as amended by a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended by adding new reference standards ASTM E 1886, ASTM E 1996, and ANSI/DASMA 115 to read as follows:

ASTM

ASTM International 100 Barr Harbor Drive West Conshohocken, PA 19428-2959

<u>Standard Reference Number</u>	<u>Title</u>	<u>Referenced in code section number</u>
<u>E 1886-06</u>	<u>Standard Test Method for Performance of Exterior Doors, and Impact Protective Systems Impacted to Cyclic Pressure Differentials</u>	<u>609.1.2</u>
<u>E 1996-09</u>	<u>Standard Specification for Performance of Exterior Doors, and Impact Protective Systems Impacted by Hurricanes</u>	<u>609.1.2, 1609.1.2.1</u>

DASMA

Door and Access Systems Manufacturers Association International 1300 Su
2851

<u>Standard reference number</u>	<u>Title</u>	<u>Referenced in code section number</u>
<u>115-05</u>	<u>Standard Method for Testing Sectional Rolling Doors: Determination of Structural Under Missile Impact and Cyclic Win</u>	<u>609.1.2.2</u>

§ 5. Chapter 15 of the New York city mechanical code, as amended by a local law of the city of New

York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, is amended by adding new reference standard AMCA 550 as follows:

AMCA Air Movement and Control Association International 30 West Univ

<u>Standard Reference Number</u>	<u>Title</u>	<u>Referenced in code section number</u>
<u>550-09</u>	<u>Test Method for High Velocity Resistant Louvers</u>	<u>W401.6.1, 501.2.2.1</u>

§ 6. This local law shall take effect on the same date as a local law of the city of New York for the year 2013 amending the administrative code of the city of New York, the New York city plumbing code, the New York city building code, the New York city mechanical code and the New York city fuel gas code, relating to bringing such codes up to date with the 2009 editions of the international building, mechanical, fuel gas and plumbing codes, as proposed in Intro. 1056, takes effect.

JCH
10/22/2013 8:53 PM