



Legislation Details (With Text)

**File #:** Int 1310-2016 **Version:** \* **Name:** Requiring DOB to report on the efficacy of outdoor reset controls.

**Type:** Introduction **Status:** Filed (End of Session)

**In control:** Committee on Housing and Buildings

**On agenda:** 10/27/2016

**Enactment date:** **Enactment #:**

**Title:** A Local Law in relation to requiring the department of buildings to report on the efficacy of outdoor reset controls

**Sponsors:** Costa G. Constantinides, Margaret S. Chin

**Indexes:** Report Required

**Attachments:** 1. Summary of Int. No. 1310, 2. Int. No. 1310

Date	Ver.	Action By	Action	Result
10/27/2016	*	City Council	Introduced by Council	
10/27/2016	*	City Council	Referred to Comm by Council	
12/31/2017	*	City Council	Filed (End of Session)	

Int. No. 1310

By Council Members Constantinides and Chin

A Local Law in relation to requiring the department of buildings to report on the efficacy of outdoor reset controls

Be it enacted by the Council as follows:

Section 1. As used in this local law, the term “outdoor reset control” means a device that is capable of (i) monitoring the outside temperature with a sensor located on the exterior of a building, (ii) monitoring the internal building temperature using a sensor located at either the location furthest from the heat source in the building, or in the area of the building that is hardest to heat, and (iii) transmitting the temperature data to the heating plant to control the heat level in the building.

§ 2. By no later than December 31, 2017, the department of buildings shall prepare and file with the mayor and the council, and post on its website, a report analyzing whether outdoor reset controls improve energy efficiency, and, if so, the feasibility of requiring the installation of such controls in all residential

buildings.

§ 3. This local law takes effect immediately.

MPC  
LS #8436  
10/20/16 3:26pm