



## Legislation Details

|                        |   |                     |   |              |  |
|------------------------|---|---------------------|---|--------------|--|
| <b>File #:</b>         | Res 1441-2012   | <b>Version:</b>     | * | <b>Name:</b> | NYS Public Safety Commission to require utilities to conduct stray voltage testing on all electric facilities accessible to the public every 6 months and inspection of all electric facilities every 2 years. |
| <b>Type:</b>           | Resolution  | <b>Status:</b>      |   |              | Filed  |
|                        |   | <b>In control:</b>  |   |              | Committee on Transportation  |
| <b>On agenda:</b>      | 7/25/2012   |                     |   |              |  |
| <b>Enactment date:</b> |   | <b>Enactment #:</b> |   |              |  |
| <b>Title:</b>          | Resolution calling upon the New York State Public Safety Commission to require utilities to conduct stray voltage testing on all electric facilities accessible to the public every six months and inspection of all electric facilities every two years. |                     |   |              |  |
| <b>Sponsors:</b>       | Peter F. Vallone, Jr., Letitia James, G. Oliver Koppell, Jumaane D. Williams, Ruben Wills   |                     |   |              |  |
| <b>Indexes:</b>        |   |                     |   |              |  |
| <b>Attachments:</b>    |   |                     |   |              |  |

| Date       | Ver. | Action By    | Action                      | Result |
|------------|------|--------------|-----------------------------|--------|
| 7/25/2012  | *    | City Council | Introduced by Council       |        |
| 7/25/2012  | *    | City Council | Referred to Comm by Council |        |
| 12/31/2013 | *    | City Council | Filed (End of Session)      |        |