

## The New York City Council

## Legislation Details (With Text)

File #: Int 0407-2004 Version: \* Name: In relation to the electrical code.

Type: Introduction Status: Enacted

In control: Committee on Housing and Buildings

On agenda: 7/21/2004

Title: A Local Law to amend the administrative code of the city of New York, in relation to the electrical

code.

Sponsors: Madeline T. Provenzano, Leroy G. Comrie, Jr., Michael C. Nelson, Philip Reed, Larry B. Seabrook,

Kendall Stewart, David I. Weprin, (by request of the Mayor)

Indexes:

Attachments: 1. Hearing Transcript 9/8, 2. Memo In Support, 3. Committee Report 9/8, 4. Committee Report 9/27, 5.

Fiscal Impact Statement, 6. Hearing Transcript 9/27, 7. Local Law, 8. Hearing Transcript - Stated

Meeting 9/28/04

Date	Ver.	Action By	Action	Result
7/21/2004	*	City Council	Introduced by Council	
7/21/2004	*	City Council	Referred to Comm by Council	
9/8/2004	*	Committee on Housing and Buildings	Hearing Held by Committee	
9/8/2004	*	Committee on Housing and Buildings	Laid Over by Committee	
9/27/2004	*	Committee on Housing and Buildings	Hearing Held by Committee	
9/27/2004	*	Committee on Housing and Buildings	Approved by Committee	Pass
9/28/2004	*	City Council	Approved by Council	Pass
9/28/2004	*	City Council	Sent to Mayor by Council	
10/14/2004	*	Mayor	Hearing Held by Mayor	
10/14/2004	*	Mayor	Signed Into Law by Mayor	
10/19/2004	*	City Council	Recved from Mayor by Council	

Int. No. 407

By Council Member Provenzano, Comrie, Nelson, Reed, Seabrook, Stewart and Weprin (by request of the Mayor)

A Local Law to amend the administrative code of the city of New York, in relation to the electrical code.

Be it enacted by the Council as follows:

Section 1. Section 27-3025 of the administrative code of the city of New York is amended by adding the following New York city amendments, 352.10(I) and 352.12(G), to the list of New York city amendments to the 2002 NEC to read as follows:

- 2002 NEC New York City Amendment
- Add a new subsection 352.10(I) to read as follows:
  - (I) In any residential building or dwelling unit not exceeding three floors above grade.
- 352.12 (G) Add a new subsection 352.12(G) to read as follows:
  - (G) In any nonresidential building, rigid nonmetallic conduit shall be concealed within non-plenum walls, floors and ceilings where the walls, floors and ceilings provide a thermal barrier of material that has at least a one hour rated assembly as identified in listings of fire-rated assemblies.
  - § 2. This local law shall take effect immediately.