Legislation Details (With Text)

File #:	Int 1006-2026 **Version:** *	**Name:**	Cleaning requirements for cooling towers.
Type:	Introduction	**Status:**	Laid Over in Committee
		In control:	Committee on Health
On agenda:	8/13/2026		
Enactment date:		**Enactment #:**	
Title:	A Local Law to amend the administrative code of the city of New York, in relation to cleaning requirements for cooling towers		
Sponsors:			
Indexes:			
Attachments:	1. Summary of Int. No. 1006, 2. Int. No. 1006, 3. Memorandum in Support, 4. August 13, 2026 - Stated Meeting Agenda, 5. Committee Report 9/2/26, 6. Fiscal Impact Statement - City Council, 7. Hearing Testimony 9/2/26, 8. Hearing Transcript 9/2/26, 9. Hearing Transcript - Stated Meeting 8-13-26		

Date	Ver.	Action By	Action	Result
8/13/2026	*	City Council	Introduced by Council	
8/13/2026	*	City Council	Referred to Comm by Council	
9/2/2026	*	Committee on Health	Hearing Held by Committee	
9/2/2026	*	Committee on Health	Laid Over by Committee	

Int. No. 1006

By Council Members Maloney, Salaam, Epstein and Narcisse

A Local Law to amend the administrative code of the city of New York, in relation to cleaning requirements for cooling towers

Be it enacted by the Council as follows:

Section 1. Subdivision d of section 17-194.1 of the administrative code of the city of New York, as added by local law number 77 of the year 2015, is amended to read as follows:

d. Cleaning and disinfection [after extended shut-down]. At a minimum, an owner shall [clean]:

1. Clean and disinfect cooling towers that are shut-down for more than [five] 5 days. Cleaning and disinfection shall occur within 15 days before the use of such tower[.]; and

2. Clean and disinfect cooling towers at least 3 times a year, including at least 1 time in June or July.

§ 2. This local law takes effect immediately.

powered by Legistar™

NY
LS #25214
8/5/2026 9:30 AM